JILLA PANCHAYATH, HAVERI

PRIMARY HEALTH CENTRE, DEVIHOSUR

Dist & Tq : Haveri

Sl.No/PHCK/ 78 Date: 01/09/2026

CERTIFICATE

Reference:

1) Request Letter of Rashtrotthan Vidya Kendra ,Sy.No 21,Devihosur Road,Haveri-581110 Dated 27/08/2026.

****

As Per above Reference and Inspection of Rashtrotthan Vidya Kendra ,Sy.No 21,Devihosur Road,Haveri-581110, this is to certify that Safe Drinking Water and Sanitary Condition in School Premises were found to be Satisfactory in Condition.

M.R.Jan ಡಿಸೈನ್

Medical Officer
Primary Health Centre, Haveri

ವೈದ್ಯಾಧಿಕಾರಿಗಳು
ಪ್ರಾಥಮಿಕ ಆರೋಗ್ಯ ಕೇಂದ್ರ,
ದೇವಿಹೊಸೂರ ತಾ॥ಜಿ॥ ಹಾವೇರಿ.

Copy To

1. District Health and Family Welfare Officer, Haveri
2. Taluka Health Officer, Haveri
3. Office Copy

ರಾಷ್ಟ್ರೋತ್ಥಾನ ವಿದ್ಯಾ ಕೇಂದ್ರ
RASHTROTTHANA VIDYA KENDRA
HAVERI-581110. Mob: 9900380621.

Shyamala 25/9/26

Principal
Rashtrotthana Vidya Kendra
Devihosur Road, Haveri-581110.

Secretary
Rashtrotthana Vidya Kendra
Devihosur Road, Haveri-581110.

Annexure- C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. Dated: 01/09/26

It is certified that an inspection team headed by

Dr Manjunath Jaragi & (Name of Officers with designation)

from PHED

inspected the RO Plant Rashtrotana School

(Name & Address of the school) on 01/9/2026 (date of inspection) and on the basis of Water Test Report (Attached) bearing no. 65 dated 8/9/2026 of PHC Devihosur (PHED Lab) certified that the Rashtrottana School (Name of school) has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till 31/08/2029

M.R.Jan ವೈ(ಸ)

Signature with Seal

Name ವೈದ್ಯಾಧಿಕಾರಿಗಳು

Designation ಪ್ರಾಥಮಿಕ ಆರೋಗ್ಯ ಕೇಂದ್ರ

Name & Address of the Officer-in-charge

To Rashtrottana School

(Name & Address of the Institution)

Secretary
Rashtrotthana Vidya Kendra
Devihosur Road, Haveri-581111.

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

ರಾಷ್ಟ್ರೋತ್ಥಾನ ವಿದ್ಯಾ ಕೇಂದ್ರ
RASHTROTTHANA VIDYA KENDRA
HAVERI-581110. Mob: 9900380627

Shyamala 25/9/26
Principal
Rashtrotthana Vidya Kendra
Devihosur Road, Haveri-581110.

ಕಾರ್ಯನಿರ್ವಾಹಕ ಇಂಜನೀಯರವರ ಕಛೇರಿ, ಗ್ರಾಮೀಣ ಕುಡಿಯುವ ನೀರು& ನೈರ್ಮಲ್ಯ ವಿಭಾಗ, ಹಾವೇರಿ
ವಿದ್ಯಾ ನಗರ, ಹಳೇ ಜಿಲ್ಲಾ ಪಂಚಾಯತ್ ಆವರಣ, ಹಾವೇರಿ-581110, ದೂರವಾಣಿ& ಫ್ಯಾಕ್ಸ್-08375-237129,EMail :- ee.rws.hvr@gmail.com

ನಂ ಕಾನಿಇಂ/ಗ್ರಾಕುನೀ&ನೈ/ವಿಹಾ/ಕುನೀಪಪ್ರ/2026-27/1200 ದಿ: 8-9-2026

ಗೆ,
ಪ್ರಾಂಶುಪಾಲರು
ರಾಷ್ಟ್ರೋತ್ಥಾನ ವಿದ್ಯಾ ಕೇಂದ್ರ, ಹಾವೇರಿ

ಮಾನ್ಯರೇ,

ವಿಷಯ :- ನೀರಿನ ರಾಸಾಯನಿಕ ವಿಶ್ಲೇಷಣೆ ವರದಿಯನ್ನು ಸಲ್ಲಿಸುವ ಕುರಿತು.

ಉಲ್ಲೇಖ:- ತಮ್ಮ ಕಛೇರಿ ಪತ್ರ ದಿ: 31-08-2026.

*****

ಮೇಲ್ಕಾಣಿಸಿದ ವಿಷಯ ಹಾಗೂ ಉಲ್ಲೇಖಕ್ಕೆ ಸಂಬಂಧಿಸಿದಂತೆ, ತಮ್ಮ ಕಛೇರಿಯಿಂದ ಒಂದು (1) ನೀರಿನ ಮಾದರಿಯನ್ನು ರಾಸಾಯನಿಕ ವಿಶ್ಲೇಷಣೆ ಮಾಡಲು ಜಿಲ್ಲಾ ಮಟ್ಟದ ಪ್ರಯೋಗಾಲಯ ಹಾವೇರಿಯವರಿಗೆ ಸಲ್ಲಿಸಿದ್ದು, ಸದರಿ ನೀರಿನ ಮಾದರಿಯನ್ನು ಪರೀಕ್ಷಿಸಿ ಪರೀಕ್ಷಾ ವರದಿಯನ್ನು ಈ ಪತ್ರದೊಂದಿಗೆ ಲಗತ್ತಿಸಿ ಕಳುಹಿಸಲಾಗಿದೆ.

ಅಡಕ: ಒಂದು ನೀರಿನ ಮಾದರಿಗಳ ಪರೀಕ್ಷಾ ವರದಿ.

ತಮ್ಮ ವಿಶ್ವಾಸಿ

ಕಾರ್ಯನಿರ್ವಾಹಕ ಇಂಜನೀಯರ್
ಗ್ರಾಮೀಣ ಕುಡಿಯುವ ನೀರು ಮತ್ತು ನೈರ್ಮಲ್ಯ
ವಿಭಾಗ ಹಾವೇರಿ.

Secretary
Rashtrotthana Vidya Kendra
Devihosur Road, Haveri-58111

Shyamala
25/9/26
Principal
Rashtrotthana Vidya Kendra
Devihosur Road, Haveri-581110.

ರಾಷ್ಟ್ರೋತ್ಥಾನ ವಿದ್ಯಾ ಕೇಂದ್ರ
RASHTROTTHANA VIDYA KENDRA
HAVERI-581110. Mob: 9900380621

HAVERI DISTRICT WATER QUALITY TESTING LABORATORY,
RURAL DRINKING WATER AND SANITATION DEPARTMENT-HAVERI,
VIDYANAGAR OLD ZP COMPOUND,HAVERI, KARNATAKA, INDIA
e-mail: ee.rws.hvr @gmail.com /rdwsd.wqmsp.haverilab@gmail.com
Phone No:08375– 237129

District Name: Haveri Laboratory Name: Division Laboratory

TEST REPORT

Address:To,
Principal
Rashtrotthana Vidya Kendra
Sy.No 21,
Devihosur Road,Haveri-581110

Taluk:Haveri & District:Haveri

Report date:05.09.2026
Report Number:65
Sample receipt date:31.08.2026
Sample code:HAV26AUGBW65
Date of Sampling:31.08.2026
Analysis start date:01.09.2026
Analysis completion date:03.09.2026
Sample Collection method: Manual for Water Quality Analysis,RDWSD,GoK
Sample quantity: 1000 ml

Sample Particulars:Borewell Water

Sl. No	Test	Results	Acceptable Limit IS 10500:2012 RA 2023	Permissible Limit 10500:2012 RA 2023	Test Method
Description: Colourless Liquid					
1.	pH Value @25^{0}C	7.76	6.5-8.5	No Relaxation	IS 3025(Part 11):2022
2.	Specific Conductance µS/cm at @25^{0}C	1055	-	-	IS 3025(Part 14):2013
3.	Odour	Agreeable	Agreeable	Agreeable	IS 3025 (Part-5):2018
4.	Colour, Hazen,Max	5	5	15	IS 3025 (Part-4):2021
5.	Turbidity,NTU,Max	0.8	1	5	IS 3025 (Part 10):2023
6.	Total Dissolved Solids,mg/l @ 180^{0}C,mg/l,Max	658	500	2000	IS 3025 (Part 16):2023
7.	Total Alkalinity as $CaCO_3$,mg/l,Max	325.48	200	600	IS 3025 (Part 23):2023
8.	Total Hardness as $CaCO_3$,mg/l,Max	380.10	200	600	IS 3025 (Part 21):2019
9.	Calcium as Ca,mg/l,Max	82.56	75	200	IS 3025 (Part 40): 2024
10.	Magnesium as Mg,mg/l,Max	42.21	30	100	IS 3025 (Part 46): 2023
11.	Chloride as Cl,mg/l,Max	262.26	250	1000	IS 3025 (Part 32):2025
12.	Sulphate as SO_4,mg/l,Max	64.52	200	400	IS 3025 (Part 24 Sec-1):2022
13.	Fluoride as F,mg/l,Max	0.448	1	1.5	APHA 24rdEdition:4500F-D:2023
14.	Nitrate as NO_3,mg/l,Max	18.44	45	No Relaxation	APHA 24rdEdition:4500NO_3-B:2023
15.	Iron as Fe,mg/l,Max	0.211	1	No Relaxation	IS 3025 (Part 53):2024

Remark: The above tested parameters conforms that they are within the acceptable limit except TDS,Alkalinity,Total Hardness,Calcium,Magnesium,Chloride are below the permissible limit as per the specification of IS10500:2012 RA :2023

Verified by:
Junior Analyst:Bhagyashree N Bangigoudra

Authorized Signatory:
Technical Manager :Bhuvaneshwari.R.Patil

RDWSD/WQMSP/TeR/01

Secretary
Rashtrotthana Vidya Kendra
Devihosur Road, Haveri-58111.

ರಾಷ್ಟ್ರೋತ್ಥಾನ ವಿದ್ಯಾ ಕೇಂದ್ರ
RASHTROTTHANA VIDYA KENDRA
HAVERI-581110. Mob: 9900380627

Principal
Rashtrotthana Vidya Kendra
Devihosur Road, Haveri-581110.

- End of the report-

HAVERI DISTRICT WATER QUALITY TESTING LABORATORY,
RURAL DRINKING WATER AND SANITATION DEPARTMENT-HAVERI,
VIDYANAGAR OLD ZP COMPOUND,HAVERI, KARNATAKA, INDIA
e-mail: ee.rws.hvr @gmail.com /rdwsd.wqmsp.haverilab@gmail.com
Phone No:08375– 237129

District Name: Haveri Laboratory Name: Division Laboratory

TEST REPORT

Address:To,
Principal
Rashtrotthana Vidya Kendra
Sy.No 21,
Devihosur Road,Haveri-581110

Taluk:Haveri & District:Haveri

Report date:05.09.2026
Report Number:66
Sample receipt date:31.08.2026
Sample code:HAV26AUGDW66
Date of Sampling:31.08.2026
Analysis start date:01.09.2026
Analysis completion date:03.09.2026
Sample Collection method: Manual for Water Quality Analysis,RDWSD,GoK
Sample quantity: 1000 ml

Sample Particulars:Drinking Water

Sl. No	Test	Results	Acceptable Limit IS 10500:2012 RA 2023	Permissible Limit 10500:2012 RA 2023	Test Method
Description: Colourless Liquid					
1.	pH Value @25^{0}C	6.94	6.5-8.5	No Relaxation	IS 3025(Part 11):2022
2.	Specific Conductance µS/cm at @25^{0}C	97	-	-	IS 3025(Part 14):2013
3.	Odour	Agreeable	Agreeable	Agreeable	IS 3025 (Part-5):2018
4.	Taste	Agreeable	Agreeable	Agreeable	IS 3025 (Part-8):2023
5.	Colour, Hazen,Max	5	5	15	IS 3025 (Part-4):2021
6.	Turbidity,NTU,Max	0.5	1	5	IS 3025 (Part 10):2023
7.	Total Dissolved Solids,mg/l @ 180^{0}C,mg/l,Max	60	500	2000	IS 3025 (Part 16):2023
8.	Total Alkalinity as $CaCO_3$,mg/l,Max	12.36	200	600	IS 3025 (Part 23):2023
9.	Total Hardness as $CaCO_3$,mg/l,Max	36.39	200	600	IS 3025 (Part 21):2019
10.	Calcium as Ca,mg/l,Max	6.47	75	200	IS 3025 (Part 40): 2024
11.	Magnesium as Mg,mg/l,Max	4.90	30	100	IS 3025 (Part 46): 2023
12.	Chloride as Cl,mg/l,Max	9.71	250	1000	IS 3025 (Part 32):2025
13.	Sulphate as SO_4,mg/l,Max	6.35	200	400	IS 3025 (Part 24 Sec-1):2022
14.	Fluoride as F,mg/l,Max	0.149	1	1.5	APHA 24rdEdition:4500F-D:2023
15.	Nitrate as NO_3,mg/l,Max	1.50	45	No Relaxation	APHA 24rdEdition:4500NO_3-B:2023
16.	Iron as Fe,mg/l,Max	0.102	1	No Relaxation	IS 3025 (Part 53):2024

Remark:The above tested parameters conforms that they are within the acceptable limit as per the specification of IS10500:2012 RA:2023

Verified by:
Junior Analyst:Bhagyashree N Bangigoudra

Authorized Signatory:
Technical Manager :Bhuvaneshwari.R.Patil

RDWSD/WQMSP/TeR/01

Secretary
Rashtrotthana Vidya Kendra
Devihosur Road, Haveri-58111.

ರಾಷ್ಟ್ರೋತ್ಥಾನ ವಿದ್ಯಾ ಕೇಂ
RASHTROTTHANA VIDYA KEN
HAVERI-581110. Mob: 9900380

25/9/26
Principal
Rashtrotthana Vidya Kendra
Devihosur Road, Haveri-581110.

-End of the report-